


LUMINAIRE PHOTOMETRIC TEST REPORT


Test:U:239.9V I:0.0486A P:10.34W PF:0.8865 Lamp Flux:833.48x1 lm		
NAME: DEEP DOWN MINI_WHT_SLE G7 09mm_250mA_3000K CRI90_50 DEG		
MFR.: DARKON		

DATA OF LAMP		PHOTOMETRIC DATA Eff: 80.61 lm/W			
MODEL	SLE G7 09mm 12001m	Imax(cd)	764.9	S/MH(C0/180)	0.93
NOMINAL POWER(W)		LOR(%)	100.0	S/MH(C90/270)	0.94
RATED VOLTAGE(V)	230.0	TOTAL FLUX(lm)	833.48	η UP,DN(C0-180)	0.0,50.2
NOMINAL FLUX(lm)	833.48	CIE CLASS	DIRECT	η UP,DN(C180-360)	0.0,49.8
LAMPS INSIDE	1	η up (%)	0.0	CIBSE SHR NOM	0.50
TEST VOLTAGE(V)	230	η down (%)	100.0	CIBSE SHR MAX	0.70

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JEFF
Test Date:23 February 2023

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity:65.0%
Test Distance:7.995m [K=1.0000]
Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:

γ	C0	C45	C90	C135	C180	C225	C270	C315	γ	Φ zone	Φ total	%lum, lamp
10	736.3	745.5	762.9	762.5	760.0	754.5	755.6	741.1	0- 10	70.54	70.54	8.46,8.46
20	661.9	659.5	670.0	660.7	642.9	640.8	669.0	680.1	10- 20	202.1	272.6	32.7,32.7
30	516.0	495.8	475.6	456.8	460.3	470.9	504.9	530.1	20- 30	269.8	542.4	65.1,65.1
40	115.6	112.3	109.1	105.6	105.7	105.8	109.9	112.2	30- 40	154.1	696.6	83.6,83.6
50	54.85	54.58	55.02	55.75	55.38	54.04	54.11	54.72	40- 50	59.93	756.5	90.8,90.8
60	23.84	24.63	25.61	26.36	26.30	25.29	24.19	23.61	50- 60	33.27	789.7	94.8,94.8
70	18.49	19.32	20.36	21.08	20.91	19.81	18.73	18.22	60- 70	22.36	812.1	97.4,97.4
80	9.539	10.47	11.37	11.81	11.48	10.42	9.493	9.174	70- 80	15.98	828.1	99.4,99.4
90	0.0803	0.0547	0.0509	0.0836	0.0912	0.0547	0.0619	0.0618	80- 90	5.398	833.5	100,100
100									90-100			
110									100-110			
120									110-120			
130									120-130			
140									130-140			
150									140-150			
160									150-160			
170									160-170			
180									170-180			
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

Conical surface Flux(90deg): 730.27 lm

%lum = 87.6%

%lamp = 87.6%

Conical surface Flux(120deg): 789.75 lm

%lum = 94.8%


%lamp = 94.8%

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JEFF
Test Date:23 February 2023

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity:65.0%
Test Distance:7.995m [K=1.0000]
Remarks:

LUMINANCE LIMITATION CURVES

Test:U:239.9V I:0.0486A P:10.34W PF:0.8865 Lamp Flux:833.48x1 lm		
NAME: DEEP DOWN MINI_WHT_SLE G7 09mm_250mA_3000K CRI90_50 DEG		
MFR.: DARKON		



LUMINANCE cd/(m2)		
G (DEG)	C0/180	C90/270
85	40321	49687
80	42165	50378
75	41890	47736
70	41497	45822
65	39138	42532
60	36602	39425
55	48299	49932
50	65501	65883
45	82783	82180


C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: JEFF
Test Date: 23 February 2023

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity: 65.0%
Test Distance: 7.995m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:239.9V I:0.0486A P:10.34W PF:0.8865 Lamp Flux:833.48x1 lm		
NAME: DEEP DOWN MINI_WHT_SLE G7 09mm_250mA_3000K CRI90_50 DEG		
MFR.: DARKON		

ρ_{cc}	80%			70%			50%			30%			10%			0
ρ_w	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
ρ_{fc}	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Coefficients of Utilization(CU)									
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	.00
1.0	1.09	1.06	1.04	1.07	1.04	1.02	1.03	1.01	.99	.99	.97	.96	.96	.94	.93	.91
2.0	1.00	.96	.92	.99	.94	.91	.95	.92	.89	.92	.89	.87	.89	.87	.85	.83
3.0	.93	.87	.82	.91	.86	.82	.88	.84	.80	.86	.82	.79	.84	.81	.78	.76
4.0	.86	.80	.75	.85	.79	.74	.82	.77	.74	.80	.76	.73	.78	.75	.72	.70
5.0	.80	.73	.69	.79	.73	.68	.77	.72	.68	.75	.71	.67	.74	.70	.66	.65
6.0	.74	.68	.63	.74	.67	.63	.72	.67	.63	.71	.66	.62	.69	.65	.62	.60
7.0	.70	.63	.59	.69	.63	.58	.68	.62	.58	.66	.61	.58	.65	.61	.57	.56
8.0	.65	.59	.54	.65	.59	.54	.64	.58	.54	.63	.57	.54	.62	.57	.54	.52
9.0	.61	.55	.51	.61	.55	.51	.60	.54	.51	.59	.54	.50	.58	.54	.50	.49
10.0	.58	.52	.48	.57	.52	.48	.57	.51	.47	.56	.51	.47	.55	.50	.47	.46



C Range: 0 - 360DEG

C Interval: 22.5DEG

Test Speed: HIGH

Temperature:25.3DEG

Operators:JEFF

Test Date:23 February 2023

γ Range: 0 - 90DEG

γ Interval: 1.0DEG

Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.295

Humidity:65.0%

Test Distance:7.995m [K=1.0000]

Remarks:

WEC AND CCEC

Test:U:239.9V I:0.0486A P:10.34W PF:0.8865 Lamp Flux:833.48x1 lm		
NAME: DEEP DOWN MINI_WHT_SLE G7 09mm_250mA_3000K CRI90_50 DEG		
MFR.: DARKON		

pcc	80%			70%			50%			30%			10%			0	
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0	
pfc	20%			20%			20%			20%			20%			0	
RCR	RCR:Room Cavity Ratio						Wall Exitance Coefficients (WEC)										
0.0																	
1.0	.208	.118	.037	.201	.115	.036	.188	.108	.034	.177	.102	.033	.166	.096	.031		
2.0	.197	.108	.033	.191	.105	.032	.180	.100	.031	.170	.095	.030	.161	.091	.029		
3.0	.185	.098	.029	.180	.096	.029	.171	.093	.028	.162	.089	.027	.154	.085	.026		
4.0	.174	.091	.027	.170	.089	.026	.162	.086	.026	.154	.083	.025	.147	.080	.024		
5.0	.165	.084	.024	.161	.083	.024	.154	.080	.024	.147	.078	.023	.141	.075	.023		
6.0	.156	.078	.022	.152	.077	.022	.146	.075	.022	.140	.073	.021	.135	.071	.021		
7.0	.148	.073	.021	.145	.072	.021	.139	.070	.020	.134	.069	.020	.129	.067	.020		
8.0	.141	.069	.019	.138	.068	.019	.133	.066	.019	.128	.065	.019	.124	.064	.019		
9.0	.134	.065	.018	.132	.064	.018	.127	.063	.018	.123	.062	.018	.119	.060	.017		
10.0	.128	.061	.017	.126	.061	.017	.122	.060	.017	.118	.059	.017	.114	.058	.017		

pcc	80%			70%			50%			30%			10%			0	
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0	
pfc	20%			20%			20%			20%			20%			0	
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients (CCEC)										
0.0	.190	.190	.190	.163	.163	.163	.111	.111	.111	.064	.064	.064	.020	.020	.020		
1.0	.173	.157	.142	.148	.135	.123	.101	.093	.085	.058	.054	.049	.019	.017	.016		
2.0	.160	.132	.110	.137	.114	.095	.094	.079	.066	.054	.046	.039	.017	.015	.013		
3.0	.148	.114	.086	.127	.098	.075	.087	.068	.052	.050	.040	.031	.016	.013	.010		
4.0	.138	.099	.069	.119	.086	.060	.082	.060	.043	.047	.035	.025	.015	.011	.008		
5.0	.130	.088	.057	.112	.076	.050	.077	.053	.035	.045	.031	.021	.014	.010	.007		
6.0	.123	.079	.047	.105	.068	.041	.073	.048	.029	.042	.028	.017	.014	.009	.006		
7.0	.116	.071	.040	.100	.062	.035	.069	.043	.025	.040	.026	.015	.013	.008	.005		
8.0	.110	.065	.034	.095	.057	.030	.066	.040	.021	.038	.023	.013	.012	.008	.004		
9.0	.105	.060	.030	.091	.052	.026	.063	.037	.019	.037	.022	.011	.012	.007	.004		
10.0	.100	.056	.026	.086	.049	.023	.060	.034	.016	.035	.020	.010	.011	.007	.003		

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JEFF
Test Date:23 February 2023

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity:65.0%
Test Distance:7.995m [K=1.0000]
Remarks:

UGR(Unified Glare Rating) Table

Test:U:239.9V I:0.0486A P:10.34W PF:0.8865 Lamp Flux:833.48x1 lm										
NAME: DEEP DOWN MINI_WHT_SLE G7 09mm_250mA_3000K						CRI90_50 DEG				
MFR.: DARKON										
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
x = 2H y = 2H	24.4	25.4	24.6	25.6	25.8	24.3	25.4	24.6	25.6	25.8
3H	25.0	25.9	25.2	26.1	26.4	25.0	26.0	25.3	26.2	26.4
4H	25.3	26.3	25.6	26.5	26.7	25.5	26.4	25.8	26.7	26.9
6H	25.7	26.6	26.0	26.8	27.1	26.0	26.8	26.3	27.1	27.3
8H	25.8	26.7	26.1	26.9	27.2	26.2	27.0	26.5	27.3	27.5
12H	25.9	26.7	26.3	27.0	27.3	26.3	27.1	26.6	27.4	27.7
4H 2H	24.5	25.4	24.7	25.6	25.8	24.4	25.4	24.7	25.6	25.8
3H	25.3	26.1	25.6	26.4	26.7	25.4	26.2	25.7	26.5	26.8
4H	25.9	26.6	26.2	26.9	27.2	26.0	26.8	26.4	27.1	27.4
6H	26.4	27.0	26.8	27.4	27.7	26.7	27.3	27.1	27.7	28.0
8H	26.6	27.2	27.0	27.6	27.9	27.0	27.6	27.4	27.9	28.3
12H	26.8	27.3	27.2	27.7	28.1	27.2	27.7	27.6	28.1	28.5
8H 4H	26.1	26.7	26.5	27.0	27.4	26.3	26.9	26.6	27.2	27.6
6H	26.8	27.3	27.2	27.7	28.1	27.1	27.6	27.5	28.0	28.4
8H	27.1	27.5	27.5	28.0	28.4	27.5	27.9	27.9	28.3	28.8
12H	27.3	27.7	27.8	28.2	28.6	27.8	28.2	28.3	28.6	29.1
12H 4H	26.1	26.7	26.5	27.0	27.4	26.3	26.8	26.7	27.2	27.6
6H	26.9	27.3	27.3	27.7	28.2	27.1	27.6	27.6	28.0	28.4
8H	27.2	27.6	27.7	28.0	28.5	27.6	27.9	28.0	28.4	28.9
Variations with the observer position at spacings:										
S = 1.0H	+ 0.5 / - 0.6					+ 0.4 / - 0.5				
1.5H	+ 0.7 / - 0.4					+ 0.5 / - 0.3				
2.0H	+ 1.0 / - 0.7					+ 0.9 / - 0.5				

CIE Pub.117 Corrected 833.5 lm Total Lamp Luminous Flux. (8log(F/F0) = -0.6)

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JEFF
Test Date:23 February 2023

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity:65.0%
Test Distance:7.995m [K=1.0000]
Remarks:

UTILIZATION FACTORS TABLE

Test:U:239.9V I:0.0486A P:10.34W PF:0.8865 Lamp Flux:833.48x1 lm		
NAME: DEEP DOWN MINI_WHT_SLE G7 09mm_250mA_3000K CRI90_50 DEG		
MFR.: DARKON		


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS (PERCENT) $k(RI) \times RCR = 5$									
$k = 0.60$	81	74	70	81	74	70	80	73	69	65
0.80	89	82	78	89	82	78	87	81	77	73
1.00	95	88	84	94	87	83	92	88	83	78
1.25	99	93	89	98	92	88	96	91	87	83
1.50	102	97	92	101	96	92	99	94	91	86
2.00	106	101	97	104	100	96	101	98	95	89
2.50	108	103	100	106	102	99	103	100	97	90
3.00	110	106	102	108	104	101	104	101	99	92
4.00	112	109	106	110	107	105	106	104	102	95
5.00	114	111	109	111	109	107	107	106	104	96
ROOM INDEX	UF (total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHRNOM = 1.25		

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.3DEG
 Operators: JEFF
 Test Date: 23 February 2023

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.295
 Humidity: 65.0%
 Test Distance: 7.995m [K=1.0000]
 Remarks:

ISOCANDELA DIAGRAM

Test:U:239.9V I:0.0486A P:10.34W PF:0.8865 Lamp Flux:833.48x1 lm		
NAME: DEEP DOWN MINI_WHT_SLE G7 09mm_250mA_3000K CRI90_50 DEG		
MFR.: DARKON		




C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JEFF
Test Date:23 February 2023

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity:65.0%
Test Distance:7.995m [K=1.0000]
Remarks:

AAI Figure

Test:U:239.9V I:0.0486A P:10.34W PF:0.8865 Lamp Flux:833.48x1 lm		
NAME: DEEP DOWN MINI_WHT_SLE G7 09mm_250mA_3000K CRI90_50 DEG		
MFR.: DARKON		




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: JEFF
Test Date: 23 February 2023

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity: 65.0%
Test Distance: 7.995m [K=1.0000]
Remarks:

ISOLUX DIAGRAM

Test:U:239.9V I:0.0486A P:10.34W PF:0.8865 Lamp Flux:833.48x1 lm		
NAME: DEEP DOWN MINI_WHT_SLE G7 09mm_250mA_3000K CRI90_50 DEG		
MFR.: DARKON		



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JEFF
Test Date:23 February 2023

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity:65.0%
Test Distance:7.995m [K=1.0000]
Remarks:

LED Avg.L Report

Test:U:239.9V I:0.0486A P:10.34W PF:0.8865 Lamp Flux:833.48x1 lm		
NAME: DEEP DOWN MINI_WHT_SLE G7 09mm_250mA_3000K CRI90_50 DEG		
MFR.: DARKON		


AvgL	cd/m2
L_0~180 (65) av	41568
L_0~180 (75) av	45278
L_0~180 (85) av	44411
L_90~270 (65) av	41216
L_90~270 (75) av	44932
L_90~270 (85) av	44315
L_45 (65) av	41352
L_45 (75) av	45084
L_45 (85) av	44413

Standard: GB/T 29293-2012

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JEFF
Test Date:23 February 2023

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity:65.0%
Test Distance:7.995m [K=1.0000]
Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: JEFF
Test Date: 23 February 2023

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity: 65.0%
Test Distance: 7.995m [K=1.0000]
Remarks:

