


LUMINAIRE PHOTOMETRIC TEST REPORT


Test:U:240.1V I:0.0688A P:15.44W PF:0.9351 Lamp Flux:1418.77x1 lm		
NAME: BARREL_WHT_35 DEG_350mA_4000K CRI90	TYPE:LED	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:1
MFR.: DARKON	SUR.:	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA Eff: 91.88 lm/W			
MODEL	TRIDONIC SLE G7 09MM	Imax(cd)	3197	S/MH(C0/180)	0.59
NOMINAL POWER(W)		LOR(%)	100.0	S/MH(C90/270)	0.58
RATED VOLTAGE(V)	230.0	TOTAL FLUX(lm)	1418.8	η UP,DN(C0-180)	0.0,50.9
NOMINAL FLUX(lm)	1418.77	CIE CLASS	DIRECT	η UP,DN(C180-360)	0.0,49.1
LAMPS INSIDE	1	η up(%)	0.0	CIBSE SHR NOM	0.50
TEST VOLTAGE(V)	230	η down(%)	100.0	CIBSE SHR MAX	0.60

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JEFF
Test Date:10 August 2023

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity:65.0%
Test Distance:7.892m [K=1.0000]
Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:

γ	C0	C45	C90	C135	C180	C225	C270	C315	γ	Φ zone	Φ total	%lum, lamp
10	2645	2670	2679	2683	2677	2647	2618	2625	0- 10	279.7	279.7	19.7,19.7
20	1319	1351	1365	1358	1340	1301	1283	1291	10- 20	547.3	827.0	58.3,58.3
30	395.4	413.0	421.4	415.2	401.8	384.7	378.7	383.4	20- 30	356.6	1184	83.4,83.4
40	97.61	103.0	108.3	105.3	99.08	94.82	92.99	93.97	30- 40	131.7	1315	92.7,92.7
50	34.65	35.69	37.71	35.99	35.28	34.55	34.32	34.16	40- 50	44.49	1360	95.8,95.8
60	23.20	23.48	24.27	23.69	23.64	23.58	23.43	23.27	50- 60	25.38	1385	97.6,97.6
70	14.82	14.92	15.15	15.02	14.98	14.82	14.77	14.77	60- 70	19.09	1404	99,99
80	6.521	6.636	6.641	6.587	6.452	6.313	6.363	6.476	70- 80	11.11	1415	99.8,99.8
90	0.0550	0.0623	0.0734	0.0587	0.0624	0.0477	0.0550	0.0513	80- 90	3.423	1419	100,100
100									90-100			
110									100-110			
120									110-120			
130									120-130			
140									130-140			
150									140-150			
160									150-160			
170									160-170			
180									170-180			
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

Conical surface Flux(90deg): 1342.4 lm

%lum = 94.6%
%lamp = 94.6%

Conical surface Flux(120deg): 1385.1 lm


%lum = 97.6%
%lamp = 97.6%

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JEFF
Test Date:10 August 2023

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity:65.0%
Test Distance:7.892m [K=1.0000]
Remarks:

LUMINANCE LIMITATION CURVES

Test:U:240.1V I:0.0688A P:15.44W PF:0.9351 Lamp Flux:1418.77x1 lm		
NAME: BARREL_WHT_35 DEG_350mA_4000K CRI90	TYPE:LED	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:1
MFR.: DARKON	SUR.:	Shielding Angle:



LUMINANCE cd/(m2)		
G (DEG)	C0/180	C90/270
85	15531	15811
80	15648	15934
75	16837	17008
70	18051	18460
65	18813	19401
60	19337	20228
55	19966	21251
50	22463	24443
45	31067	34292


C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JEFF
Test Date:10 August 2023

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity:65.0%
Test Distance:7.892m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:240.1V I:0.0688A P:15.44W PF:0.9351 Lamp Flux:1418.77x1 lm		
NAME: BARREL_WHT_35 DEG_350mA_4000K CRI90	TYPE:LED	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:1
MFR.: DARKON	SUR.:	Shielding Angle:

ρ_{cc}	80%			70%			50%			30%			10%			0
ρ_w	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
ρ_{fc}	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Coefficients of Utilization(CU)									
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	1.00
1.0	1.11	1.09	1.07	1.09	1.07	1.05	1.05	1.03	1.02	1.01	1.00	.99	.98	.97	.96	.94
2.0	1.04	1.01	.97	1.03	.99	.96	.99	.97	.94	.96	.94	.92	.94	.92	.90	.89
3.0	.98	.94	.90	.97	.93	.89	.94	.91	.88	.92	.89	.87	.90	.87	.85	.84
4.0	.93	.88	.84	.92	.87	.84	.90	.86	.83	.88	.84	.82	.86	.83	.81	.79
5.0	.88	.83	.79	.87	.82	.79	.86	.81	.78	.84	.80	.77	.82	.79	.77	.75
6.0	.84	.79	.75	.83	.78	.75	.82	.77	.74	.80	.77	.74	.79	.76	.73	.72
7.0	.80	.75	.71	.79	.74	.71	.78	.74	.71	.77	.73	.70	.76	.72	.70	.69
8.0	.77	.71	.68	.76	.71	.68	.75	.70	.67	.74	.70	.67	.73	.69	.67	.66
9.0	.73	.68	.65	.73	.68	.65	.72	.67	.64	.71	.67	.64	.70	.67	.64	.63
10.0	.70	.65	.62	.70	.65	.62	.69	.65	.62	.68	.64	.62	.68	.64	.61	.60



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JEFF
Test Date:10 August 2023

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity:65.0%
Test Distance:7.892m [K=1.0000]
Remarks:

WEC AND CCEC

Test:U:240.1V I:0.0688A P:15.44W PF:0.9351 Lamp Flux:1418.77x1 lm		
NAME: BARREL_WHT_35 DEG_350mA_4000K CRI90	TYPE:LED	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:1
MFR.: DARKON	SUR.:	Shielding Angle:

pcc	80%			70%			50%			30%			10%			0	
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0	
pfc	20%			20%			20%			20%			20%			0	
RCR	RCR:Room Cavity Ratio						Wall Exitance Coefficients (WEC)										
0.0																	
1.0	.169	.096	.030	.162	.092	.029	.149	.086	.027	.138	.080	.026	.127	.074	.024		
2.0	.158	.087	.027	.153	.084	.026	.142	.079	.025	.133	.074	.023	.124	.070	.022		
3.0	.149	.079	.024	.144	.077	.023	.135	.073	.022	.127	.069	.021	.119	.066	.020		
4.0	.140	.073	.021	.136	.071	.021	.128	.068	.020	.121	.065	.020	.115	.062	.019		
5.0	.132	.067	.020	.129	.066	.019	.122	.064	.019	.116	.061	.018	.110	.059	.018		
6.0	.125	.063	.018	.122	.062	.018	.116	.060	.017	.111	.058	.017	.106	.056	.017		
7.0	.119	.059	.017	.116	.058	.017	.111	.056	.016	.107	.055	.016	.102	.053	.016		
8.0	.113	.055	.016	.111	.055	.015	.107	.053	.015	.102	.052	.015	.099	.051	.015		
9.0	.108	.052	.015	.106	.052	.015	.102	.051	.014	.099	.049	.014	.095	.048	.014		
10.0	.104	.050	.014	.102	.049	.014	.098	.048	.014	.095	.047	.013	.092	.046	.013		

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients (CCEC)									
0.0	.190	.190	.190	.163	.163	.163	.111	.111	.111	.064	.064	.064	.020	.020	.020	
1.0	.171	.157	.146	.146	.135	.125	.100	.093	.087	.057	.054	.050	.018	.017	.016	
2.0	.154	.133	.114	.132	.114	.099	.091	.079	.069	.052	.046	.040	.017	.015	.013	
3.0	.141	.113	.091	.121	.098	.079	.083	.068	.056	.048	.040	.033	.015	.013	.011	
4.0	.130	.099	.075	.111	.085	.065	.077	.059	.046	.044	.035	.027	.014	.011	.009	
5.0	.120	.087	.062	.103	.075	.054	.071	.052	.038	.041	.031	.023	.013	.010	.007	
6.0	.112	.077	.052	.097	.067	.045	.067	.047	.032	.039	.028	.019	.012	.009	.006	
7.0	.105	.069	.044	.091	.060	.038	.063	.042	.027	.036	.025	.016	.012	.008	.005	
8.0	.099	.063	.038	.085	.055	.033	.059	.038	.023	.034	.023	.014	.011	.007	.005	
9.0	.094	.057	.033	.081	.050	.029	.056	.035	.020	.033	.021	.012	.011	.007	.004	
10.0	.089	.053	.029	.077	.046	.025	.053	.032	.018	.031	.019	.011	.010	.006	.004	

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JEFF
Test Date:10 August 2023

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity:65.0%
Test Distance:7.892m [K=1.0000]
Remarks:

UGR(Unified Glare Rating) Table

Test:U:240.1V I:0.0688A P:15.44W PF:0.9351 Lamp Flux:1418.77x1 lm										
NAME: BARREL_WHT_35 DEG_350mA_4000K CRI90					TYPE:LED			WEIGHT:		
SPEC.:					DIM.:			SERIAL No.:1		
MFR.: DARKON					SUR.:			Shielding Angle:		
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
x = 2H y = 2H	18.7	19.5	18.9	19.7	19.8	19.0	19.8	19.2	20.0	20.1
3H	19.4	20.2	19.6	20.4	20.6	19.6	20.4	19.9	20.6	20.8
4H	19.7	20.5	20.0	20.7	20.9	20.0	20.7	20.2	20.9	21.1
6H	20.0	20.7	20.3	20.9	21.2	20.2	20.9	20.5	21.1	21.4
8H	20.1	20.8	20.4	21.0	21.3	20.3	21.0	20.6	21.2	21.5
12H	20.2	20.8	20.5	21.1	21.3	20.4	21.0	20.7	21.3	21.6
4H 2H	18.9	19.6	19.1	19.8	20.1	19.1	19.9	19.4	20.1	20.3
3H	19.8	20.4	20.1	20.7	21.0	20.0	20.7	20.3	20.9	21.2
4H	20.3	20.8	20.6	21.1	21.4	20.5	21.0	20.8	21.3	21.6
6H	20.6	21.2	21.0	21.5	21.8	20.8	21.3	21.2	21.7	22.0
8H	20.8	21.3	21.2	21.6	22.0	21.0	21.5	21.4	21.8	22.2
12H	20.9	21.4	21.3	21.7	22.1	21.1	21.5	21.5	21.9	22.3
8H 4H	20.4	20.9	20.8	21.2	21.6	20.6	21.1	21.0	21.4	21.8
6H	20.9	21.3	21.3	21.7	22.1	21.1	21.5	21.5	21.9	22.3
8H	21.2	21.5	21.6	21.9	22.4	21.3	21.7	21.7	22.1	22.5
12H	21.4	21.7	21.8	22.1	22.6	21.5	21.8	22.0	22.2	22.7
12H 4H	20.4	20.8	20.8	21.2	21.6	20.6	21.0	21.0	21.4	21.8
6H	21.0	21.3	21.4	21.7	22.2	21.1	21.5	21.6	21.9	22.3
8H	21.2	21.5	21.7	22.0	22.4	21.4	21.7	21.8	22.1	22.6
Variations with the observer position at spacings:										
S = 1.0H	+ 0.8 / - 0.9					+ 0.9 / - 0.9				
1.5H	+ 1.8 / - 0.8					+ 2.0 / - 0.8				
2.0H	+ 0.7 / - 0.4					+ 0.8 / - 0.4				

CIE Pub.117 Corrected 1419 lm Total Lamp Luminous Flux. (8log(F/F0) = 1.2)

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JEFF
Test Date:10 August 2023

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity:65.0%
Test Distance:7.892m [K=1.0000]
Remarks:

UTILIZATION FACTORS TABLE

Test:U:240.1V I:0.0688A P:15.44W PF:0.9351 Lamp Flux:1418.77x1 lm		
NAME: BARREL_WHT_35 DEG_350mA_4000K CRI90	TYPE:LED	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:1
MFR.: DARKON	SUR.:	Shielding Angle:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS (PERCENT) $k(RI) \times RCR = 5$									
$k = 0.60$	87	81	77	87	81	77	86	80	77	73
0.80	94	88	85	94	88	85	93	88	84	80
1.00	99	93	89	98	93	89	96	92	89	85
1.25	103	97	94	102	97	93	100	96	93	88
1.50	105	101	97	104	100	97	102	98	96	91
2.00	108	104	101	107	103	100	104	101	98	93
2.50	110	106	103	108	105	102	105	102	100	94
3.00	111	108	105	110	107	104	106	104	102	95
4.00	114	111	108	112	109	107	108	106	104	97
5.00	115	113	111	113	111	109	109	107	106	98
ROOM INDEX	UF (total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHR NOM = 1.25		

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature: 25.3DEG
 Operators: JEFF
 Test Date: 10 August 2023

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.295
 Humidity: 65.0%
 Test Distance: 7.892m [K=1.0000]
 Remarks:

ISOCANDELA DIAGRAM

Test:U:240.1V I:0.0688A P:15.44W PF:0.9351 Lamp Flux:1418.77x1 lm		
NAME: BARREL_WHT_35 DEG_350mA_4000K CRI90	TYPE:LED	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:1
MFR.: DARKON	SUR.:	Shielding Angle:




C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JEFF
Test Date:10 August 2023

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity:65.0%
Test Distance:7.892m [K=1.0000]
Remarks:

AAI Figure

Test:U:240.1V I:0.0688A P:15.44W PF:0.9351 Lamp Flux:1418.77x1 lm		
NAME: BARREL_WHT_35 DEG_350mA_4000K CRI90	TYPE:LED	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:1
MFR.: DARKON	SUR.:	Shielding Angle:




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JEFF
Test Date:10 August 2023

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity:65.0%
Test Distance:7.892m [K=1.0000]
Remarks:

ISOLUX DIAGRAM

Test:U:240.1V I:0.0688A P:15.44W PF:0.9351 Lamp Flux:1418.77x1 lm		
NAME: BARREL_WHT_35 DEG_350mA_4000K CRI90	TYPE:LED	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:1
MFR.: DARKON	SUR.:	Shielding Angle:



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JEFF
Test Date:10 August 2023

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity:65.0%
Test Distance:7.892m [K=1.0000]
Remarks:

LED Avg.L Report

Test:U:240.1V I:0.0688A P:15.44W PF:0.9351 Lamp Flux:1418.77x1 lm		
NAME: BARREL_WHT_35 DEG_350mA_4000K CRI90	TYPE:LED	WEIGHT:
SPEC.:	DIM.:	SERIAL No.:1
MFR.: DARKON	SUR.:	Shielding Angle:


AvgL	cd/m2
L_0~180 (65) av	18981
L_0~180 (75) av	16816
L_0~180 (85) av	15198
L_90~270 (65) av	19179
L_90~270 (75) av	16757
L_90~270 (85) av	15207
L_45 (65) av	19017
L_45 (75) av	16775
L_45 (85) av	15180

Standard: GB/T 29293-2012

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JEFF
Test Date:10 August 2023

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity:65.0%
Test Distance:7.892m [K=1.0000]
Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: JEFF
Test Date: 10 August 2023

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity: 65.0%
Test Distance: 7.892m [K=1.0000]
Remarks:

