


LUMINAIRE PHOTOMETRIC TEST REPORT


Test:U:239.8V I:0.0639A P:14.22W PF:0.9272 Lamp Flux:1047.85x1 lm		
NAME: DEEPER DOWN_SLE G7 09mm_350mA_3000K CRI90_32 DEGR:LED		WEIGHT:
SPEC.:	DIM.:	SERIAL No.:1
MFR.: DARKON	SUR.:	Shielding Angle:

DATA OF LAMP		PHOTOMETRIC DATA Eff: 73.70 lm/W			
MODEL	SLE G7 09mm 1200lm	Imax(cd)	1254	S/MH(C0/180)	0.86
NOMINAL POWER(W)		LOR(%)	100.0	S/MH(C90/270)	0.84
RATED VOLTAGE(V)	230.0	TOTAL FLUX(lm)	1047.9	η UP,DN(C0-180)	0.0,50.2
NOMINAL FLUX(lm)	1047.85	CIE CLASS	DIRECT	η UP,DN(C180-360)	0.0,49.8
LAMPS INSIDE	1	η up(%)	0.0	CIBSE SHR NOM	0.75
TEST VOLTAGE(V)	230	η down(%)	100.0	CIBSE SHR MAX	0.90

LUMINOUS INTENSITY DISTRIBUTION DIAGRAM



C0 PLANE ISOLUX DIAGRAM (UNIT:lx)



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JEFF
Test Date:16 January 2024

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity:65.0%
Test Distance:7.890m [K=1.0000]
Remarks:

ZONAL FLUX DIAGRAM

ZONAL FLUX DIAGRAM:

γ	C0	C45	C90	C135	C180	C225	C270	C315	γ	Φ zone	Φ total	%lum,lamp
10	1170	1165	1189	1181	1163	1147	1158	1158	0- 10	116.1	116.1	11.1,11.1
20	850.6	822.8	845.5	859.7	858.0	825.8	851.4	859.6	10- 20	282.1	398.2	38,38
30	558.1	562.7	573.5	595.2	601.6	582.4	571.6	566.7	20- 30	326.8	725.0	69.2,69.2
40	115.2	116.2	115.1	117.2	115.2	110.8	113.5	116.8	30- 40	188.4	913.4	87.2,87.2
50	48.41	48.33	47.59	46.65	46.39	46.66	47.13	47.86	40- 50	59.85	973.3	92.9,92.9
60	28.02	27.44	26.68	26.15	26.12	26.53	27.31	28.01	50- 60	28.55	1002	95.6,95.6
70	21.81	21.30	20.49	19.85	19.73	20.09	20.91	21.69	60- 70	24.15	1026	97.9,97.9
80	11.66	11.24	10.52	9.863	9.646	9.957	10.71	11.45	70- 80	16.62	1043	99.5,99.5
90	0.0366	0.0330	0.0367	0.0367	0.0403	0.0366	0.0367	0.0367	80- 90	5.261	1048	100,100
100									90-100			
110									100-110			
120									110-120			
130									120-130			
140									130-140			
150									140-150			
160									150-160			
170									160-170			
180									170-180			
DEG	LUMINOUS INTENSITY:cd									UNIT:lm		

Conical surface Flux(90deg): 948.81 lm

%lum = 90.5%

%lamp = 90.5%

Conical surface Flux(120deg): 1001.8 lm

%lum = 95.6%


%lamp = 95.6%

C Range: 0 - 360DEG
 C Interval: 22.5DEG
 Test Speed: HIGH
 Temperature:25.3DEG
 Operators:JEFF
 Test Date:16 January 2024

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
 Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.295
 Humidity:65.0%
 Test Distance:7.890m [K=1.0000]
 Remarks:

LUMINANCE LIMITATION CURVES

Test:U:239.8V I:0.0639A P:14.22W PF:0.9272 Lamp Flux:1047.85x1 lm		
NAME: DEEPER DOWN_SLE G7 09mm_350mA_3000K CRI90_32 DEE:LED	WEIGHT:	
SPEC.:	DIM.:	SERIAL No.:1
MFR.: DARKON	SUR.:	Shielding Angle:



LUMINANCE cd/(m2)		
G (DEG)	C0/180	C90/270
85	48612	42293
80	51720	46585
75	50194	46357
70	49127	46060
65	46832	44305
60	43175	41038
55	40153	38252
50	58014	56934
45	84208	84023


C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JEFF
Test Date:16 January 2024

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity:65.0%
Test Distance:7.890m [K=1.0000]
Remarks:

CU AND LUMINAIRE BUDGETARY ESTIMATE DIAGRAM

Test:U:239.8V I:0.0639A P:14.22W PF:0.9272 Lamp Flux:1047.85x1 lm		
NAME: DEEPER DOWN_SLE G7 09mm_350mA_3000K CRI90_32 DEE:LED		WEIGHT:
SPEC.:	DIM.:	SERIAL No.:1
MFR.: DARKON	SUR.:	Shielding Angle:

ρ_{cc}	80%			70%			50%			30%			10%			0
ρ_w	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
ρ_{fc}	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio			Coefficients of Utilization(CU)												
0.0	1.19	1.19	1.19	1.16	1.16	1.16	1.11	1.11	1.11	1.06	1.06	1.06	1.02	1.02	1.02	1.00
1.0	1.10	1.07	1.05	1.08	1.05	1.03	1.04	1.02	.00	.00	.98	.97	.96	.95	.94	.92
2.0	1.01	.97	.93	.00	.96	.92	.96	.93	.90	.93	.91	.88	.91	.88	.86	.85
3.0	.94	.89	.85	.93	.88	.84	.90	.86	.82	.88	.84	.81	.85	.82	.80	.78
4.0	.88	.82	.77	.87	.81	.77	.84	.80	.76	.82	.78	.75	.80	.77	.74	.73
5.0	.82	.76	.71	.81	.75	.71	.79	.74	.70	.78	.73	.70	.76	.72	.69	.68
6.0	.77	.71	.66	.76	.70	.66	.75	.69	.65	.73	.69	.65	.72	.68	.65	.63
7.0	.72	.66	.62	.72	.66	.61	.70	.65	.61	.69	.64	.61	.68	.64	.60	.59
8.0	.68	.62	.58	.68	.62	.58	.66	.61	.57	.65	.61	.57	.64	.60	.57	.55
9.0	.64	.58	.54	.64	.58	.54	.63	.58	.54	.62	.57	.54	.61	.57	.54	.52
10.0	.61	.55	.51	.60	.55	.51	.60	.54	.51	.59	.54	.51	.58	.54	.51	.49



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JEFF
Test Date:16 January 2024

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity:65.0%
Test Distance:7.890m [K=1.0000]
Remarks:

WEC AND CCEC

Test:U:239.8V I:0.0639A P:14.22W PF:0.9272 Lamp Flux:1047.85x1 lm		
NAME: DEEPER DOWN_SLE G7 09mm_350mA_3000K CRI90_32 DEE:LED	WEIGHT:	
SPEC.:	DIM.:	SERIAL No.:1
MFR.: DARKON	SUR.:	Shielding Angle:

pcc	80%			70%			50%			30%			10%			0	
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0	
pfc	20%			20%			20%			20%			20%			0	
RCR	RCR:Room Cavity Ratio						Wall Exitance Coefficients (WEC)										
0.0																	
1.0	.197	.112	.035	.190	.108	.034	.177	.102	.033	.166	.096	.031	.155	.090	.029		
2.0	.186	.102	.031	.180	.099	.031	.170	.094	.029	.160	.090	.028	.151	.085	.027		
3.0	.175	.093	.028	.170	.091	.027	.161	.087	.027	.153	.084	.026	.145	.080	.025		
4.0	.165	.086	.025	.161	.084	.025	.153	.081	.024	.146	.078	.024	.139	.075	.023		
5.0	.156	.080	.023	.152	.078	.023	.145	.076	.022	.139	.073	.022	.133	.071	.021		
6.0	.148	.074	.021	.145	.073	.021	.139	.071	.021	.133	.069	.020	.128	.067	.020		
7.0	.141	.069	.020	.138	.069	.020	.132	.067	.019	.127	.065	.019	.122	.064	.019		
8.0	.134	.065	.018	.131	.065	.018	.126	.063	.018	.122	.062	.018	.118	.060	.018		
9.0	.128	.062	.017	.125	.061	.017	.121	.060	.017	.117	.059	.017	.113	.057	.017		
10.0	.122	.059	.016	.120	.058	.016	.116	.057	.016	.112	.056	.016	.109	.055	.016		

pcc	80%			70%			50%			30%			10%			0
pw	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	50%	30%	10%	0
pfc	20%			20%			20%			20%			20%			0
RCR	RCR:Room Cavity Ratio						Ceiling Cavity Exitance Coefficients (CCEC)									
0.0	.190	.190	.190	.163	.163	.163	.111	.111	.111	.064	.064	.064	.020	.020	.020	
1.0	.173	.157	.143	.148	.135	.123	.101	.093	.085	.058	.054	.050	.019	.017	.016	
2.0	.158	.132	.111	.135	.114	.096	.093	.079	.067	.054	.046	.039	.017	.015	.013	
3.0	.146	.114	.088	.125	.098	.076	.086	.068	.053	.050	.040	.031	.016	.013	.010	
4.0	.136	.099	.071	.117	.086	.062	.080	.060	.043	.046	.035	.026	.015	.011	.008	
5.0	.128	.088	.058	.110	.076	.051	.075	.053	.036	.044	.031	.021	.014	.010	.007	
6.0	.120	.078	.049	.103	.068	.042	.071	.048	.030	.041	.028	.018	.013	.009	.006	
7.0	.113	.071	.041	.098	.061	.036	.067	.043	.025	.039	.025	.015	.013	.008	.005	
8.0	.108	.065	.035	.093	.056	.031	.064	.039	.022	.037	.023	.013	.012	.008	.004	
9.0	.102	.060	.031	.088	.052	.027	.061	.036	.019	.036	.021	.011	.012	.007	.004	
10.0	.098	.055	.027	.084	.048	.023	.058	.034	.017	.034	.020	.010	.011	.007	.003	

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JEFF
Test Date:16 January 2024

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity:65.0%
Test Distance:7.890m [K=1.0000]
Remarks:

UGR(Unified Glare Rating) Table

Test:U:239.8V I:0.0639A P:14.22W PF:0.9272 Lamp Flux:1047.85x1 lm										
NAME: DEEPER DOWN_SLE G7 09mm_350mA_3000K CRI90_32 DEE:LED								WEIGHT:		
SPEC.:				DIM.:				SERIAL No.:1		
MFR.: DARKON				SUR.:				Shielding Angle:		
ceiling/cavity	0.7	0.7	0.5	0.5	0.3	0.7	0.7	0.5	0.5	0.3
walls	0.5	0.3	0.5	0.3	0.3	0.5	0.3	0.5	0.3	0.3
working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2
Room dimensions	Viewed crosswise					Viewed endwise				
x = 2H y = 2H	24.0	25.0	24.2	25.1	25.3	24.0	25.0	24.2	25.2	25.3
3H	24.7	25.6	25.0	25.8	26.1	24.7	25.6	24.9	25.8	26.0
4H	25.2	26.1	25.5	26.3	26.5	25.1	25.9	25.3	26.2	26.4
6H	25.6	26.4	25.9	26.7	26.9	25.4	26.3	25.7	26.5	26.8
8H	25.8	26.6	26.1	26.8	27.1	25.6	26.4	25.9	26.6	26.9
12H	25.9	26.7	26.2	26.9	27.2	25.7	26.4	26.0	26.7	27.0
4H 2H	24.1	25.0	24.4	25.2	25.4	24.1	25.0	24.4	25.2	25.4
3H	25.1	25.9	25.4	26.1	26.4	25.1	25.8	25.4	26.1	26.4
4H	25.7	26.4	26.1	26.7	27.1	25.6	26.3	26.0	26.6	26.9
6H	26.4	27.0	26.7	27.3	27.7	26.2	26.8	26.5	27.1	27.5
8H	26.6	27.2	27.0	27.5	27.9	26.4	27.0	26.8	27.3	27.7
12H	26.8	27.3	27.2	27.7	28.1	26.5	27.1	27.0	27.4	27.8
8H 4H	26.0	26.5	26.4	26.9	27.3	25.9	26.4	26.3	26.8	27.1
6H	26.7	27.2	27.2	27.6	28.0	26.6	27.0	27.0	27.4	27.8
8H	27.1	27.5	27.6	27.9	28.4	26.9	27.3	27.3	27.7	28.2
12H	27.4	27.7	27.9	28.2	28.7	27.1	27.5	27.6	27.9	28.4
12H 4H	26.0	26.5	26.4	26.9	27.3	25.9	26.4	26.3	26.8	27.2
6H	26.8	27.2	27.3	27.6	28.1	26.6	27.1	27.1	27.5	27.9
8H	27.2	27.6	27.7	28.0	28.5	27.0	27.4	27.5	27.8	28.3
Variations with the observer position at spacings:										
S = 1.0H	+ 0.4 / - 0.5					+ 0.4 / - 0.5				
1.5H	+ 0.7 / - 0.5					+ 0.7 / - 0.5				
2.0H	+ 0.8 / - 0.4					+ 0.9 / - 0.4				

CIE Pub.117 Corrected 1048 lm Total Lamp Luminous Flux. (8log(F/F0) = 0.2)

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JEFF
Test Date:16 January 2024

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity:65.0%
Test Distance:7.890m [K=1.0000]
Remarks:

UTILIZATION FACTORS TABLE

Test:U:239.8V I:0.0639A P:14.22W PF:0.9272 Lamp Flux:1047.85x1 lm		
NAME: DEEPER DOWN_SLE G7 09mm_350mA_3000K CRI90_32 DEE:LED	WEIGHT:	
SPEC.:	DIM.:	SERIAL No.:1
MFR.: DARKON	SUR.:	Shielding Angle:


REFLECTANCE										
Ceiling	0.8	0.8	0.8	0.7	0.7	0.7	0.5	0.5	0.5	0
Walls	0.7	0.5	0.3	0.7	0.5	0.3	0.7	0.5	0.3	0
Working plane	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0.2	0
ROOM INDEX	UTILIZATION FACTORS (PERCENT) $k(RI) \times RCR = 5$									
$k = 0.60$	84	77	73	83	77	72	82	76	72	68
0.80	91	85	81	91	84	80	89	84	80	76
1.00	96	90	86	95	89	85	94	89	85	81
1.25	100	95	91	99	94	90	97	93	89	85
1.50	103	98	94	102	97	94	100	96	93	88
2.00	107	102	98	105	101	97	102	99	96	90
2.50	109	104	101	107	103	100	104	101	98	92
3.00	110	107	103	109	105	102	105	102	100	93
4.00	113	110	107	111	108	106	107	105	103	96
5.00	114	111	109	112	110	108	108	106	105	97
ROOM INDEX	UF (total)									Direct
According to DIN EN 13032-2 2004			Suspended					SHR NOM = 1.25		

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: JEFF
Test Date: 16 January 2024

γ Range: 0 - 90DEG
 γ Interval: 1.0DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity: 65.0%
Test Distance: 7.890m [K=1.0000]
Remarks:

ISOCANDELA DIAGRAM

Test:U:239.8V I:0.0639A P:14.22W PF:0.9272 Lamp Flux:1047.85x1 lm		
NAME: DEEPER DOWN_SLE G7 09mm_350mA_3000K CRI90_32 DEE:LED	WEIGHT:	
SPEC.:	DIM.:	SERIAL No.:1
MFR.: DARKON	SUR.:	Shielding Angle:




C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: JEFF
Test Date: 16 January 2024

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity: 65.0%
Test Distance: 7.890m [K=1.0000]
Remarks:

AAI Figure

Test:U:239.8V I:0.0639A P:14.22W PF:0.9272 Lamp Flux:1047.85x1 lm		
NAME: DEEPER DOWN_SLE G7 09mm_350mA_3000K CRI90_32 DEE:LED	WEIGHT:	
SPEC.:	DIM.:	SERIAL No.:1
MFR.: DARKON	SUR.:	Shielding Angle:




Note:The Curves indicate the illuminated area and the average illumination when the luminaire is at different distance.

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: JEFF
Test Date: 16 January 2024

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity: 65.0%
Test Distance: 7.890m [K=1.0000]
Remarks:

ISOLUX DIAGRAM

Test:U:239.8V I:0.0639A P:14.22W PF:0.9272 Lamp Flux:1047.85x1 lm		
NAME: DEEPER DOWN_SLE G7 09mm_350mA_3000K CRI90_32 DEE:LED	WEIGHT:	
SPEC.:	DIM.:	SERIAL No.:1
MFR.: DARKON	SUR.:	Shielding Angle:



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JEFF
Test Date:16 January 2024

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity:65.0%
Test Distance:7.890m [K=1.0000]
Remarks:

LED Avg.L Report

Test:U:239.8V I:0.0639A P:14.22W PF:0.9272 Lamp Flux:1047.85x1 lm		
NAME: DEEPER DOWN_SLE G7 09mm_350mA_3000K CRI90_32 DEE:LED	WEIGHT:	
SPEC.:	DIM.:	SERIAL No.:1
MFR.: DARKON	SUR.:	Shielding Angle:


AvgL	cd/m2
L_0~180 (65) av	44959
L_0~180 (75) av	46978
L_0~180 (85) av	42797
L_90~270 (65) av	44814
L_90~270 (75) av	46804
L_90~270 (85) av	42634
L_45 (65) av	44883
L_45 (75) av	46891
L_45 (85) av	42707

Standard: GB/T 29293-2012

C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature:25.3DEG
Operators:JEFF
Test Date:16 January 2024

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System:EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity:65.0%
Test Distance:7.890m [K=1.0000]
Remarks:

Planar Illuminance Curve



C Range: 0 - 360DEG
C Interval: 22.5DEG
Test Speed: HIGH
Temperature: 25.3DEG
Operators: JEFF
Test Date: 16 January 2024

γ Range: 0 - 90DEG
γ Interval: 1.0DEG
Test System: EVERFINE GO-2000A_V1 SYSTEM V2.0.295
Humidity: 65.0%
Test Distance: 7.890m [K=1.0000]
Remarks:

